



Legislation Details (With Text)

File #:	15-5683	Version:	1	Name:	
Type:	Consent Item	Status:		Approved	
File created:	5/22/2017	In control:		City Council Business Meeting	
On agenda:	6/26/2017	Final action:		6/26/2017	
Title:	Lee S. Dukes Water Treatment Plant Tank Rehabilitation				
Attachments:	1. Lee S. Dukes WTP Map				

Date	Ver.	Action By	Action	Result
6/26/2017	1	City Council Business Meeting	Approve	Pass

Lee S. Dukes Water Treatment Plant Tank Rehabilitation

Action:

Award a contract in the amount of \$378,769 to the lowest responsive bidder, Superior Industrial Maintenance Company, for the Lee S. Dukes Water Treatment Plant Clarifiers and Thickener Rehabilitation project.

Staff Resource(s):

Barry Gullet, Charlotte Water
Carl Wilson, Charlotte Water

Explanation

- The City owns and maintains three water treatment plants in Mecklenburg County. The Lee S. Dukes Water Treatment Plant (WTP) is in Huntersville.
- Clarifiers and thickeners are large cylindrical concrete tanks used in the water treatment process. This contract provides for the routine inspection, mechanical maintenance, and restoration of these tanks, which are required on a 15- to 20-year maintenance cycle.
- On April 18, 2017 the City issued an Invitation to Bid for Lee S. Dukes Water Treatment Plant Clarifier and Thickener Rehabilitation project; three bids were received from interested service providers.
- Superior Industrial Maintenance Company was selected as the lowest responsive, responsible bidder.
- The project is anticipated to be complete by the first quarter of 2018.

Charlotte Business INclusion

No subcontracting goals was established because there are no subcontracting opportunities (Part B: Section 2.3 of the Charlotte Business INclusion Policy).

Fiscal Note

Funding: Charlotte Water Community Investment Plan

Attachment(s)

Map