

## Legislation Text

---

File #: 15-8620, Version: 1

---

### Four Mile Creek Tributary Sanitary Sewer Improvements

#### **Action:**

**Approve a contract in the amount of \$2,643,353.89 to the lowest responsive bidder State Utility Contractors, Inc. for construction of the Four Mile Creek Tributary Sanitary Sewer Improvements Project.**

#### **Staff Resource(s):**

Angela Lee, Charlotte Water  
Ron Hargrove, Charlotte Water  
Carl Wilson, Charlotte Water

#### **Explanation**

- This project includes the replacement of approximately 4,300 linear feet of 15 and eight-inch diameter gravity sewer, including a segment of gravity sewer underneath Interstate 485, to address sanitary sewer capacity limitations in the area.
- The Four Mile Creek Tributary gravity sewer serves customers located along the Interstate 485 corridor between Weddington Road, Pleasant Plains Road, and McKee Road in the Town of Matthews (adjacent to Council District 7).
- The area serviced by this gravity sewer is experiencing a high rate of infill development and the existing gravity sewer cannot accommodate projected growth.
- On July 6, 2018, the City issued an Invitation to Bid; two bids were received.
- State Utility Contractors, Inc. was selected as the lowest responsive, responsible bidder.
- The project is anticipated to be complete in the second quarter of 2019.

#### **Charlotte Business INclusion**

Established MSBE Goal: 7.00%

Committed MSBE Goal: 7.17%

State Utility Contractors, Inc. met the established subcontracting goal and has committed 7.17% (\$189,500) of the total contract amount to the following certified firm(s) (Part B: Section 3 of the Charlotte Business INclusion Policy):

- AMP Utility Distribution Services, LLC (SBE) (\$105,200) (material supplier)
- Sanders Constructors, Inc. (SBE) (\$41,700) (clearing)
- All Points Trucking, Inc. (SBE) (\$30,500) (hauling)
- P&TL, Inc. (SBE) (\$12,100) (erosion control)

#### **Fiscal Note**

Funding: Charlotte Water Community Investment Plan

#### **Attachment(s)**

Map